

SECTION 08361

STEEL SECTIONAL OVERHEAD DOORS

This guide specification has been prepared by C.H.I. Overhead Doors to assist design professionals in the preparation of a specification section covering steel sectional overhead doors, available with 20, 24, and 26 gage panels, insulated or non-insulated. Refer to C.H.I. Overhead Doors literature for specific model numbers and additional information on these products.

This specification may be used as the basis for developing either a project specification or an office master specification. Since it has been prepared according to the principles established in the *Manual of Practice* published by The Construction Specifications Institute (CSI), it may be used in conjunction with most commercially available master specifications systems with minor editing.

Other C.H.I. Overhead Doors products are covered by the following guide specifications, available from C.H.I. Overhead Doors:

Section 08334 - Overhead Coiling Doors.

Section 08335 - Overhead Coiling Fire Doors.

Section 08336 - Overhead Coiling Shutters.

Section 08337 - Overhead Coiling Fire Shutters.

Section 08362 - Aluminum Sectional Overhead Doors.

The following should be noted in using this guide specification:

Notes are included to assist the user in editing the section to suit project requirements. These notes are included as hidden text, and can be revealed or hidden by one of the following methods:

Microsoft Word: From the pull-down menus select TOOLS, then OPTIONS. Under the tab labeled VIEW, select or deselect the HIDDEN TEXT option.

Corel WordPerfect: From the pull-down menus select VIEW, then select or deselect the HIDDEN TEXT option.

Optional text requiring a selection by the user is enclosed within brackets, e.g.: "Section [09000.] [____.]"

Items requiring user input are enclosed within brackets, e.g.: "Section [____ - ____]."

Optional paragraphs are separated by an "OR" statement, e.g.:

*** OR ***

"Green" requirements are included for projects requiring LEED certification, and are included as green text. For additional information on LEEDS, visit the U.S. Green Building Council website at www.usgbc.org.

This guide specification is available in a variety of electronic formats to suit most popular word processing programs. Please contact C.H.I. Overhead Doors at 800-677-2650 or www.chiohd.com.

PART 1 - GENERAL

1.1 SUMMARY

- A. Section Includes:
1. [Manually] [Electrically] operated steel sectional overhead doors.
 2. Operating hardware, controls, and supports.

B. Related Sections:

Edit the following paragraphs to suit project requirements and to coordinate with other sections in the project manual.

1. Division 1: Administrative, procedural, and temporary work requirements.
2. Section [09910 - Paints:] [_____ - _____]: Field painting of doors.

Include the following paragraph for electrically operated doors.

3. Section [_____] - [_____]: Connection to power supply and control devices.

1.2 REFERENCES

Include only those reference standards that are included within the text of this section. If statements are included in Division 1 addressing the edition dates of standards, delete edition dates from the following statements.

- A. ASTM International (ASTM) (www.astm.org) A653/A653M-03 - Standard Specification for Specification for Steel Sheet, Zinc-Coated (Galvanized) or Zinc-Iron Alloy-Coated (Galvannealed) by the Hot-Dip Process.

1.3 SYSTEM DESCRIPTION

Include the following paragraph for exterior doors.

- A. Design doors to withstand:

Include the following paragraph for exterior doors.

1. Positive and negative design wind loads [in accordance with Building Code.] [of [__] PSF.]

In the following paragraph, 10,000 cycles is standard.

2. Cycle life of [10,000] [25,000] [50,000] [100,000] [__] cycles.

In the following paragraph, select operation to suit project requirements.

- B. Operation: [Electric.] [Manual.] [Chain hoist.]

In the following paragraph, select track type to suit project requirements.

- C. Track and Operating Hardware: [Standard lift] [Vertical lift] [High lift] [Roof pitch] [Low headroom] type.

1.4 SUBMITTALS

- A. Submittals for Review:

1. Shop Drawings: Indicate opening dimensions and required tolerances, connection details, anchorage spacing, hardware locations, and installation details.
2. Product Data: Provide information on component construction, anchorage method, and hardware.

- B. Closeout Submittals:

1. Operation and Maintenance Data.

Include the following for projects requiring LEED certification. Credits are available for the use of recycled materials, and also for regional materials if the project is located within a 500 mile radius of the C.H.I. fabrication facility.

- C. Sustainable Design Submittals:

1. Recycled products: Indicate percentage of recycled material used in manufacture of products, and percentage classified as post consumer.
2. Regional products: Indicate location of product manufacturer and distance from manufacturer to project site.

1.5 WARRANTIES

- A. Provide manufacturer's one year warranty against defects in materials and workmanship.

PART 2 - PRODUCTS

2.1 MANUFACTURERS

- A. Contract Documents are based on Model [_____] by C.H.I. Overhead Doors.

Include the following paragraph if substitutions are allowed; coordinate with Division 1 requirements.

- B. Substitutions: Under provisions of [Section _____.] [Division 1.]

**** OR ****

Include the following paragraph if substitutions are not allowed.

- C. Substitutions: Not permitted.

2.2 MATERIALS

- A. Galvanized Steel Sheet:
1. ASTM A653/A653M, Structural Quality, G60 coating class.

Include the following paragraph for projects requiring LEED certification.

2. Recycled content: Minimum [75] [__] percent, with minimum [40] [__] percent classified as post consumer.

Include the following paragraph for glazed panels; edit to suit project requirements. Choose only insulating glass for insulated doors.

- B. Glazing: Clear [1/8 inch float glass] [1/4 inch tempered glass.] [1/8 inch polycarbonate sheet.] [insulating glass.]

2.3 COMPONENTS

Include the following for a deep ribbed pan style door.

- A. Door Sections:
1. Type: Deep ribbed, pan style.
 2. Material: Galvanized steel.
 3. Gage: [20.] [24.] [26.]
 4. Thickness: Nominally 2 inches.
 5. Rails: Tongue-and-groove.
 6. End caps: Wrap-around box style, 18 gage galvanized steel, full height of section, riveted to inside rails and face of door.
 7. Insulation: 1-1/2 inches thick, CFC-free polystyrene.
 8. Inside face: [Vinyl, laminated to insulation.] [27 gage galvanized steel, attached with plastic retainer strips.]

**** OR ****

Include the following for a sandwich style door.

- B. Door Sections:
1. Type: Micro-grooved sandwich style.
 2. Material: Galvanized steel.
 3. Gage: Per design requirements.
 4. Thickness: Nominally 2 inches.
 5. Rails: Tongue-and-groove.
 6. End caps: Wrap-around box style, 20 gage galvanized steel, full height of section.
 7. Insulation: [1-13/16 inches thick, CFC-free polystyrene.] [95 percent closed cell, foamed-in-place polyurethane with thermal break.]

Include the following paragraph for vision lites, and select desired size and pattern. Coordinate available sizes with specific door type selected.

8. Vision lites:
- a. Rectangular, [6 x 24] [12 x 24] [16 x 34] inches, set with silicone sealant and screws.
 - b. Pattern: [] wide x [] high, [centered.] [left side looking out.] [right side looking out.]

**** OR ****

Include the following paragraph for full-view glazed panels. Indicate quantity of glazed sections on drawings.

9. Glazed section: Full view type, aluminum framed.

Include the following paragraph for vehicle exhaust ports.

10. Exhaust ports: Aluminum, with hinged cover.

- C. Tracks:

In the following paragraphs, select either 2 or 3 inch tracks to suit project conditions and door size.

1. 2 inches wide, roll-formed galvanized steel, 16 gage for doors up to 10 feet high, 14 gage for doors exceeding 10 feet high.

**** OR ****

2. 3 inches wide, roll-formed 13 gage galvanized steel, with galvanized steel mounting brackets.
3. Lower track sections adjustable for weathertight fit.
4. Horizontal tracks reinforced with minimum 13 gage galvanized steel angle according to door weight and size.

- D. Hinge and Roller Assemblies: Heavy duty hinges and adjustable roller holders of galvanized steel, with floating hardened steel bearing rollers, located at top and bottom of each panel, each side.

- E. Spring Counterbalance:

1. Oil tempered torsion springs mounted on cross-header shaft supported by galvanized steel ball bearing end plates and center carrier brackets as required.
2. Counterbalance transferred to doors via aircraft quality braided steel lift cables.

- F. Bottom Weatherstripping: Vinyl weatherseal, full width of door.

Include the following paragraph if head and jamb weatherstripping are desired.

- G. Head and Jamb Weatherstripping: Flexible one piece vinyl extrusions.

In the following paragraph, select type of locking desired.

- H. Lock: [Inside slide] [Outside keyed T-handle] [Outside cylinder] type, adjustable keeper, spring activated.

Include the following paragraph for electrically operated doors. Select type of control station. Include photoelectric sensor if desired.

- I. Electric Operator:
 - 1. Power supply: [115 VAC, single phase.] [220 VAC, [single] [three] phase.] [440-480 VAC, three phase.]
 - 2. Sufficient power to operate door at average speed of 12 inches per second.
 - 3. Disconnect for [manual push-up] [chain hoist] operation in case of power failure.

In the following paragraph, select type of control station. Three-position 24VDC push button is standard.

- 4. Control station: [24 VDC;] [115 VAC;] [push button] [keyed switch] station marked [OPEN and CLOSE.] [OPEN, CLOSE, and STOP.] [Furnish [four] [] keys per station.]

Include the following paragraph for a safety device to prevent damage to doors due to obstructions in door path.

- J. Safety Device: [Photoelectric sensor; detect obstruction and reverse door without requiring door to contact obstruction.] [Electric pneumatic edge; detect obstruction and reverse door upon contact with pneumatic hose.] [Electric edge; detect obstruction and reverse door upon contact with electric strips in vinyl housing.] [Electric edge; fail-safe, self monitoring.]

Edit the following paragraph based on available finishes per C.H.I. Overhead Doors technical literature.

- K. Finish:
 - 1. Exterior panel surfaces: Baked-on enamel primer and polyester finish coat, [] color [to be selected from manufacturer's standards.]
 - 2. Interior panel surfaces: Baked-on polyester primer.

PART 3 - EXECUTION

3.1 INSTALLATION

- A. Install door assembly in accordance with manufacturer's instructions.
- B. Anchor to adjacent construction without distortion or stress.
- C. Securely brace door tracks suspended from structure. Secure tracks to structural members only.
- D. Fit and align door assembly including hardware, level and plumb, to provide smooth operation.

Include the following paragraph for head and jamb weatherstripping.

- E. Position head and jamb weatherstripping to contact door sections when closed; secure in position.

Include the following paragraph for electrically operated doors.

- F. Make wiring connections between power supply and operator and between operator and controls.

3.2 ADJUSTING

- A. Adjust to operate smoothly throughout full operating range.

END OF SECTION